

ADDENDUM NUMBER 2

CIVIC CENTER TRAILS PROJECT TOWN OF BARRINGTON, RI

Date this Addendum Issued: Friday, March 11, 2016

From: Philip Hervey, Town Planner, Barrington, RI

283 County Road, Barrington, RI

(401) 247-1900 x347 (office)

phervey@barrington.ri.gov (e-mail)

Posted 3/11/16 at:

- <http://www.barrington.ri.gov/topics/govbids.php>

GENERAL INSTRUCTIONS:

- This Addendum constitutes an integral part of the above-referenced RFP and shall be read in conjunction with the Request.
 - Where inconsistent with the original Request, or any subsequent Addendum, this Addendum shall govern.
 - It is the responsibility of all Proposers to conform to this Addendum.
 - Unless specifically changed herein, all other requirements of the Request shall remain in full force and effect and can only be modified if in writing.
-

PURPOSE OF THIS ADDENDUM:

- To answer contractor questions submitted subsequent to the Pre-Bid meeting, and prior to the 4:30 pm March 7, 2016 deadline for questions.

Questions:

1. Could you please identify the stone dust walkway areas on the plans?

RESPONSE: With the exception of Detail 4 on Sheet 5, a Stone Dust Walkway is not indentified on the plans. Accordingly, the Bidder's Base Bid should not include Stone Dust Walkway.

However, please note Item 9 in Part C. (Unit Prices) of the Bid Form. Bidders shall utilize Detail 4 on Sheet 5 to complete this line item #9 of Part C.

Comments:

2. This is a Base Bid contract. Please review the purpose of the Unit Prices, as described in Part C of the Bid Form.
3. Detail 4 on Sheet 5 incorrectly identifies the Stone Dust layer shall be four inches (4") thick. By this addendum, *this specification has been revised to three inches (3") thick.*

END OF THIS ADDENDUM

3/11/15